

CJV-U279 550kW CAT G3512LE Generator Package



Condition	New / Reconditioned
Manufacturer	Belair Power in 2013
Location	North East British Columbia
Availability	Immediate
Driven	Kato 550kW 480V/3 Phase/60Hz
Driver	Caterpillar Natural Gas G3512LE 810HP 1200RPM Has not been in service since zero hour overhaul
Fuel Usage	At full generator load (550KW) the theoretical fuel usage, based on 905 LHV and CAT engine specifications is 144,768 scfd. Fuel gas analysis required to verify for specific application
Building Notes	Skidded and Housed in gable style oilfield building and fully wired to Junction Boxes c/w 25HP Radiator fan motor, 24V engine start, exhaust fans, natural gas heaters, CAT engine control panel, generator control panel, main disconnect, interior/exterior lights





