

# CJV-U281 400kW CAT G3412TA Generator



<b>Condition</b>	Used – 19000HRS Runtime since New; 2 units available
<b>Manufactured</b>	KUDU 2014
<b>Location</b>	Lloydminster, Alberta
<b>Availability</b>	Immediate
<b>Driven</b>	400kW Stamford HCI432F1 480V/3 Phase/60Hz
<b>Driver</b>	Caterpillar G3412TA 607HP 1800RPM
<b>Fuel Usage</b>	At full generator load (400kW) the theoretical fuel usage, based on 905 LHV and CAT engine specifications is 105,911 scfd. Fuel gas analysis required to verify for specific application
<b>Building Notes</b>	Winchable Skid and Housed in 12' W x 27'L Metal building and fully wired to Junction boxes c/w Dynagen Generator control panel, interior lights, ESD push button, automated louvers, interior lights, and natural gas heaters.

