

U281 400kW CAT G3412TA Generator



Condition	Used – 19000HRS Runtime since New; 2 units available
Manufactured	KUDU 2014
Location	Lloydminster, Alberta
Availability	Immediate
Driven	400kW Stamford HCI432F1 480V/3 Phase/60Hz
Driver	Caterpillar G3412TA 607HP 1800RPM
Fuel Usage	At full generator load (400kW) the theoretical fuel usage, based on 905 LHV and CAT engine specifications is 105,911 scfd. Fuel gas analysis required to verify for specific application
Building Notes	Winchable Skid and Housed in 12' W x 27'L Metal building and fully wired to Junction boxes c/w Dynagen Generator control panel, interior lights, ESD push button, automated louvers, interior lights, and natural gas heaters.

